

CERTIFICATE OF CONFORMITY

1. HAZARDOUS LOCATION COMPONENT PER CANADIAN REQUIREMENTS

2. Certificate No: **FM19CA0077U**
3. Component:
(Type Reference and Name) **MPS S4 Combustible Gas Sensors**
4. Name of Listing Company: **Nevada Nanotech Systems Inc.**
5. Address of Listing Company: **1395 Greg St Suite 102, Sparks, Nevada 89431,
United States of America**
6. The examination and test results are recorded in confidential report number:
PR452569 dated 25th November 2019

7. FM Approvals LLC, certifies that the component described has been found to comply with the following Approval standards and other documents:

CSA C22.2 No. 60079-0:2019, CSA C22.2 No. 60079-11:2014

8. The sign 'U' placed after the certificate number indicates that this certificate must not be mistaken for a certificate for equipment or a protective system. This certificate may only be used as the basis for the certification of equipment or a protective system. This certificate is issued to the manufacturer also intended to be the holder of the equipment certificate which includes this component.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

10. Component Ratings:

Intrinsically Safe for Class I, II, & III, Division 1, Groups A, B, C, D, E, F, and G ; Class I, Zone 0, Group IIC; Zone 20, Group IIIC hazardous locations with an ambient temperature rating of -40°C to +75°C.

Certificate issued by:

J.E. Marquedant

J.E. Marquedant
VP, Manager - Electrical Systems

10 October 2024

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

F 331 (Jul 24)



SCHEDULE

Canadian Certificate of Conformity No: FM19CA0077U

11. The marking of the component shall include:

IS, Class I, II, III, Division 1, Groups A, B, C, D, E, F, G
Ex ia IIC Ga
Ex ia IIIC Da
Ta = -40°C to +75°C

12. Description of Component:

General - The MPS S4 Combustible Gas Sensors are 3, 4, or 5 pin components for use in gas detection. The sensors are designed to detect multiple gases and gas mixtures. The sensors are components installed in a gas detection system.

Ratings - The ambient operating temperature range is -40°C to +75°C.

The MPS S4 Gas Sensors have the following Energy Limiting Parameters:

Hardware Configuration: 03, 04, or 05:

Ui = 6V; Ii = 1.8A; Ci = 19.5 μF; Li = 0; Pi = 870mW.

Hardware Configuration: 23, 24, 25, or 34:

Ui = 6V; Ii = 1.8A; Ci = 8.3 μF; Li = 0; Pi = 870mW.

MPSaaa-bbccdd-ef Combustible Gas Sensor.

aaa = Product Family: Any 3 alphanumeric combination

bb = Form/Size: S4

cc = Hardware Configuration: 03, 04, 05, 23, 24, 25, or 34

dd = Software Configuration: Any 2 alphanumeric combination

e = Certification: E

f = Production Classification: Any alphanumeric combination

13. Schedule of Limitations:

1. The function of the sensor shall be verified as necessary in accordance with the appropriate performance standard.
2. The sensor shall be installed within an enclosure with a minimum ingress protection rating of IP20.
3. The intrinsically safe parameters for the sensor shall be applied to the intrinsically safe device to which the sensor is connected.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

F 331 (Jul 24)



SCHEDULE

Canadian Certificate of Conformity No: FM19CA0077U

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
25 November 2019	Original Issue.
26 February 2020	<u>Supplement 1:</u> Report Reference: – RR222046 dated 26 th February 2020. Description of the Change: Update to schedule of limitations.
11 January 2021	<u>Supplement 2:</u> Report Reference: – RR22373 dated 11 th January 2021. Description of the Change: Remove option Series S7. Various minor editorial changes to improve documentation related to the S4 form factor. Reformat model code.
5 February 2021	<u>Supplement 3:</u> Report Reference: PR469537 dated 5 th February 2021. Description of the Change(s): Correct typo in removing option Series S7.
14 June 2021	<u>Supplement 4:</u> Report Reference: RR228122 dated 14 th June 2021. Description of the Change(s): Update to Section 13 – Schedule of Limitations
27 July 2021	<u>Supplement 5:</u> Report Reference: RR228746 dated 27 th July 2021. Description of the Change(s): Ui is changed from 5.25V to 6V. Editorial changes to drawings.
25 October 2021	<u>Supplement 6:</u> Report Reference: RR229254 dated 25 th October 2021. Description of the Change(s): Hardware configuration options added for Version 2 design. New configurations have separate entity parameters with reduced capacitance.
10 October 2024	<u>Supplement 7:</u> Report Reference: PR469537 dated 10 October 2024. Description of the Change(s): Minor revisions to printed circuit assembly of MPS S4 V1. Addition of MPS S4 V3 version, identified in model numbering scheme as Hardware Configuration 34.

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

F 331 (Jul 24)

